

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 9/03/2026

It is certified that an inspection team headed by Dr. Shovanabharavaj.


(Name of Officers with designation) from T.H.O office Manvi.

(Name of Department/ Office) inspected the **B V R INTERNATIONAL SCHOOL NEAR N. S.**

**BOSERAJU CIRCLE, WARD NO:- 5, BASAVA NAGAR, MANVI-584123** On 9/03/2026;

checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year.

ಕಾಲಾಕ ಆರೋಗ್ಯಾಧಿಕಾರಿಗಳು Signature with Seal: 

ತಾ|| ಮಾನವಿ ಜಿ|| ರಾಯಚೂರು Name : Dr. Shovanabharavaj.


**TALUKA HEALTH OFFICER** Designation: T.H.O Manvi.  
**Tq : Manvi. Dt : Raichur.**


Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorized officer of the Local Body

Name & Address of the Office / Department: .....

To

**B V R INTERNATIONAL SCHOOL**  
**NEAR N. S. BOSERAJU CIRCLE,**  
**WARD NO: - 5, BASAVA NAGAR,**  
**MANVI, RAICHUR-DIST-584123**

  
**PRESIDENT**  
**BVR Memorial Education Trust (R)**  
**MANVI-584 123. Dist. Raichur**

  
**PRINCIPAL**  
**BVR INTERNATIONAL SCHOOL**  
**MANVI-584123. Dist. Raichur**



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK  
 RAICHUR DISTRICT WATER QUALITY TESTING LABORATORY - RDWSD  
 CELLAR PORTION, PRED PREMISES, RAICHUR, KARNATAKA, INDIA  
 E-mail: rdwsdwqmspraichurlab@gmail.com



TEST REPORT

TO,  
 BVR INTERNATIONAL SCHOOL  
 MANVI

SOURCE : BOREWELL

ULR NO : TC163192500000111F  
 Report date: 10/03/2026  
 Report Number: MAN26MAR0002  
 Reference: Sample receipt Form(Departmental)  
 Sample receipt date: 06/03/2026  
 Sample code: MAN26MAR0002  
 Date of Sample collection: 06/03/2026  
 Analysis start date: 07/03/2026  
 Analysis completion date: 09/03/2026  
 Sample collection protocol: APHA 24<sup>th</sup> Edition  
 Environmental Condition : 25.5° C  
 Sample quantity: 1000 mL

Sample Particulars: BORE WELL WATER

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Sample Description / Condition : Clear					
1.	Ph value @25° C	8.42	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm@ Temp 25° C	887	–	–	IS 3025 (Part-14) : 2019
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4.	Colour, Hazen Units	01	5	15	IS 3025 (Part-4) : 2021
5.	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids @ 180°C, mg/l	590	500	2000	IS 3025 (Part-16) : 2023
7.	Total Alkalinity as CaCO <sub>3</sub> , mg/l	188	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO <sub>3</sub> , mg/l	180.16	200	600	IS 3025 (Part-21) : 2019
9.	Calcium as Ca, mg/l	60.90	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	6.80	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	145.95	250	1000	IS 3025 (Part-32) : 2019
12.	Sulphate as SO <sub>4</sub> , mg/l	32	200	400	IS 3025 (Part-24) : 2022
13.	Fluoride as F, mg/l	0.78	1	1.5	APHA 24 <sup>th</sup> Edition 4500F-D:2023
14.	Nitrate as NO <sub>3</sub> , mg/l	6.88	45	No relaxation	APHA 24 <sup>th</sup> Edition 4500-NO3- B:2023
15.	Iron as Fe, mg/l	0.12	1	No relaxation	IS 3025 (Part-53) : 2024

Remarks: The given sample conforms within the Permissible limit of IS 10500:2012 RA:2018 Drinking water specification for above Tested physical & chemical parameters only.

Authorized Signatory

Senior Analyst(TM) / Junior Analyst  
 (sumitra) (Chandrika)  
 RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP
- 6) Note : BDL-Below Detection Limit. NTU : Nephelometric meter

**PRESIDENT**  
 BVR Memorial Education Trust (R)  
 MANVI-584 123. Dist. Raichur

----- End of the Report -----

**PRINCIPAL**  
 BVR INTERNATIONAL SCHOOL  
 MANVI-584123. Dist. Raichur